



सत्यमेव जयते

भारत सरकार
Government of India

विद्युत मंत्रालय

Ministry of Power

पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033

14 Golf Club Road, Tollygunj, Kolkata-700033



Tel No.:033-24239650. 24239651 FAX No.:033-24239652. 24239653 Web: www.ernc.gov.in

No-ERPC/MS/TA/PL/2017/1950

Date-22.08.2017

To,


The Executive Director (ED & CEO),
Powerlinks Transmission Ltd,
10th Floor, DLF Tower-A,
District Centre-Jasola, New Delhi-110025

Certificate of availability of Powerlinks Transmission elements in eastern region for the month of April-17, May-17 & June-17

Availability for Intra Regional Lines of Powerlinks Transmission elements in eastern region (%)*
for

Month	Availability
April, 2017	100.000 %
May, 2017	100.000 %
June, 2017	99.759 %

* Calculations as per CERC Regulations effective from 01.04.2014


(A. K. Bandyopadhyaya)
Member Secretary

Copy to: General Manager (O&P), Powerlinks Transmission Limited, Bidyut Nagar, Jalpaiguri, West Bengal, Pin-734015 (Fax: 0353 2568856)

APRIL

Availability Calculation for the month of April 17 for Powerlink Lines in ER

2017

Element Name	Attributable to PL		Attributable to Others		Act of God/Grid Incident		Outage Under the Category of Deemed		Ti	TNAi	Wi (SIL*Ckt Km)	Wi(Ti-TNAi)/Ti	100*Wi(Ti-TNAi)/(Ti*Wi)
	Hrs	Mins	Hrs	Mins	Hrs	Mins	Hrs	Min					
400 KV NSLG-KSNE-I	0	0	0	0	0	0	0	0	720	0.00	64088.856	64089	100.000
400 KV NSLG-KSNE- II	0	0	0	0	0	0	0	0	720	0.00	64088.856	64089	100.000
400 KV KSNE-NPRN-I	0	0	0	0	0	0	0	0	720	0.00	45343.374	45343.374	100.000
400 KV KSNE-NPRN-II	0	0	0	0	0	0	0	0	720	0.00	45343.374	45343	100.000
400 KV NPRN-MUZ-I	0	0	0	0	0	0	0	0	720	0.00	125705.837	125705.84	100.000
400 KV NPRN-MUZ-II	0	0	0	0	0	0	0	0	720	0.00	125705.837	125705.84	100.000
220 KV MUZ-KANTI-I	0	0	0	0	0	0	0	0	720	0.00	3174.6	3174.6	100.000
220 KV MUZ-KANTI-II	0	0	0	0	0	0	0	0	720	0.00	3174.6	3174.6	100.000
	0	0	0	0	0	0	0	0	5760		476625.334	476625.33	

Availability 1.00000

% Availability 100.000

May

Availability Calculation for the month of May 17 for Powerlink Lines in ER

2017

Element Name	Attributable to PL		Attributable to Others		Act of God/Grid Incident		Outage Under the Category of Deemed		Ti	TNAi	Wi (SIL*Ckt Km)	Wi(Ti-TNAi)/Ti	100*Wi(Ti-TNAi)/(Ti*Wi)
	Hrs	Mins	Hrs	Mins	Hrs	Mins	Hrs	Min					
400 KV NSLG-KSNE- I	0	0	0	0	0	0	0	0	744	0.00	64088.856	64089	100.000
400 KV NSLG-KSNE- II	0	0	0	0	0	0	0	0	744	0.00	64088.856	64089	100.000
400 KV KSNE-NPRN-I	0	0	0	0	0	0	0	0	744	0.00	45343.374	45343	100.000
400 KV KSNE-NPRN-II	0	0	0	0	0	0	0	0	744	0.00	45343.374	45343	100.000
400 KV NPRN-MUZ-I	0	0	0	0	0	0	0	0	744	0.00	125705.837	125705.84	100.000
400 KV NPRN-MUZ-II	0	0	8	18	0	0	0	0	735.70	0.00	125705.837	125705.84	100.000
220 KV MUZ-KANTI-I	0	0	1	57	0	0	0	0	742.05	0.00	3174.6	3174.6	100.000
220 KV MUZ-KANTI-II	0	0	1	7	0	0	0	0	742.88	0.00	3174.6	3174.6	100.000
	0	0	10	82	0	0	0	0	5940.633		476625.334	476625.33	800.000

Availability 1.00000

% Availability 100.000

JUNE

Availability Calculation for the month of June 17 for Powerlink Lines in ER

2017

Element Name	Attributable to PL		Attributable to Others		Act of God/Grid Incident		Outage Under the Category of Deemed		Ti	TNAi	Wi (SIL*Ckt Km)	Wi(Ti-TNAi)/Ti	100*Wi(Ti-TNAi)/(Ti*Wi)
	Hrs	Mins	Hrs	Mins	Hrs	Mins	Hrs	Min					
400 KV NSLG-KSNE-I	0	0	0	0	0	0	0	0	720	0.00	64088.856	64089	100.000
400 KV NSLG-KSNE- II	0	0	0	0	0	0	0	0	720	0.00	64088.856	64089	100.000
400 KV KSNE-NPRN-I	0	0	0	0	0	0	0	0	720	0.00	45343.374	45343.374	100.000
400 KV KSNE-NPRN-II	0	0	0	0	0	0	0	0	720	0.00	45343.374	45343	100.000
400 KV NPRN-MUZ-I	0	0	0	0	0	0	0	0	720	0.00	125705.837	125705.84	100.000
400 KV NPRN-MUZ-II	6	34	0	0	0	0	0	0	720	6.57	125705.837	124559.35	99.088
220 KV MUZ-KANTI-I	0	0	0	38	0	0	0	0	719.37	0.00	3174.6	3174.6	100.000
220 KV MUZ-KANTI-II	0	0	0	52	0	0	0	0	719.13	0.00	3174.6	3174.6	100.000
	6	34	0	90	0	0	0	0	5758.5		476625.334	475478.85	799.088

Availability 0.998

% Availability 99.759



Member Secretary