



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

Tel No.:033-24239650. 24239651 FAX No.:033-24239652. 24239653 Web: www.ernc.gov.in

No-ERPC/MS/TA/PL/2017-18/ 828

Date-07.05.2018

To,


The Executive Director (ED & CEO),
Powerlinks Transmission Ltd,
10th Floor, DLF Tower-A,
District Centre- Jasola, New Delhi-110025

Certificate of availability of Powerlinks Transmission elements in Eastern Region for the month of February & March-2018

Availability for Intra Regional Lines of Powerlinks Transmission elements in eastern region (%)*
for

Month	Availability
February, 2018	100.000 %
March, 2018	100.000 %

* Calculations as per CERC Regulations effective from 01.04.2014


(J. Bandyopadhyay)
Member Secretary

Copy to: General Manager (O&P), Powerlinks Transmission Limited, Bidyut Nagar, Jalpaiguri, West Bengal, Pin-734015 (Fax: 0353 2568856)

Availability Calculation for the month of February, 2018 for Powerlink Lines in ER

Element Name	Attributable to PL		Attributable to Others		Act of God/Grid Incident		Outage Under the Category of Deemed		Ti	TNAi	Wi (SIL*Ckt Km)	Wi(Ti-TNAi)/Ti	100*Wi(Ti-TNAi)/(Ti*Wi)
	Hrs	Mins	Hrs	Mins	Hrs	Mins	Hrs	Min	Hrs	Hrs			
400 KV NSLG-KSNE-I	0	0	0	0	0	0	0	0	672.0	0.00	64088.856	64088.9	100.000
400 KV NSLG-KSNE- II	0	0	0	0	0	0	0	0	672.0	0.00	64088.856	64088.9	100.000
400 KV KSNE-NPRN-I	0	0	0	0	0	0	0	0	672.0	0.00	45343.374	45343.4	100.000
400 KV KSNE-NPRN-II	0	0	0	0	0	0	0	0	672.0	0.00	45343.374	45343.4	100.000
400 KV NPRN-MUZ-I	0	0	0	0	0	0	0	0	672.0	0.00	125705.84	125705.8	100.000
400 KV NPRN-MUZ-II	0	0	0	0	0	0	0	0	672.0	0.00	125705.84	125705.8	100.000
220 KV MUZ-KANTI-I	0	0	0	0	0	0	0	0	672.0	0.00	3174.6	3174.6	100.000
220 KV MUZ-KANTI-II	0	0	0	0	0	0	0	0	672.0	0.00	3174.6	3174.6	100.000
	0	0	0	0	0	0	0	0	5376.0		476625.33	476625.33	800.000

Availability 1.00000
 % Availability 100.000

Availability Calculation for the month of March ,2018 for Powerlink Lines in ER

Element Name	Attributable to PL		Attributable to Others		Act of God/Grid Incident		Outage Under the Category of Deemed		Ti	TNAi	Wi (SIL*Ckt Km)	Wi(Ti-TNAi)/Ti	100*Wi(Ti-TNAi)/(Ti*Wi)
	Hrs	Mins	Hrs	Mins	Hrs	Mins	Hrs	Min	Hrs	Hrs			
400 KV NSLG-KSNE-I	0	0	0	0	0	0	0	0	744.0	0.00	64088.856	64088.9	100.000
400 KV NSLG-KSNE- II	0	0	0	0	0	0	0	0	744.0	0.00	64088.856	64088.9	100.000
400 KV KSNE-NPRN-I	0	0	0	0	0	0	0	0	744.0	0.00	45343.374	45343.4	100.000
400 KV KSNE-NPRN-II	0	0	1	33	0	0	0	0	742.5	0.00	45343.374	45343.4	100.000
400 KV NPRN-MUZ-I	0	0	0	0	0	0	0	0	744.0	0.00	125705.84	125705.8	100.000
400 KV NPRN-MUZ-II	0	0	0	0	0	0	0	0	744.0	0.00	125705.84	125705.8	100.000
220 KV MUZ-KANTI-I	0	0	0	0	0	0	0	0	744.0	0.00	3174.6	3174.6	100.000
220 KV MUZ-KANTI-II	0	0	0	0	0	0	0	0	744.0	0.00	3174.6	3174.6	100.000
	0	0	0	0	0	0	0	0					
	0	0	1	33	0	0	0	0	5950.5		476625.33	476625.33	800.000

Availability 1.00000
 % Availability 100.000

Jaydev Banerjee 21/5/18
 Member Secretary