



सत्यमेव जयते

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033

14 Golf Club Road, Tollygunj, Kolkata-700033



Tel No.:033-24239650, 24239651 FAX No.:033-24239652, 24239653 Web: www.ernpc.gov.in

No-ERPC/MS/TA/PL/2017-18/ 192

Date-06.04.2018

To,

The Executive Director (ED & CEO),
Powerlinks Transmission Ltd,
10th Floor, DLF Tower-A,
District Centre- Jasola, New Delhi-110025

Certificate of availability of Powerlinks Transmission elements in eastern region for the month of January-2018

Availability for Intra Regional Lines of Powerlinks Transmission elements in eastern region (%)*
for

Month	Availability
January, 2018	98.314 %

* Calculations as per CERC Regulations effective from 01.04.2014

 06/04/18
(J. Bandyopadhyay)
Member Secretary

Copy to: General Manager (O&P), Powerlinks Transmission Limited, Bidyut Nagar, Jalpaiguri, West Bengal, Pin-734015 (Fax: 0353 2568856)

JANUARY,2018

Availability Calculation for the month of January 18 for Powerlink Lines in ER

2018

Element Name	Attributable to Powerlinks		Attributable to Others		Act of God/Grid Incident		Outage Under the Category of Deemed		Ti	TNAi	Wi (SIL*Ckt Km)	Wi(Ti-TNAi)/Ti	100*Wi(Ti-TNAi)/(Ti*Wi)
	Hrs	Mins	Hrs	Mins	Hrs	Mins	Hrs	Min	Hrs	Hrs			
400 KV NSLG-KSNE-I	0	0	0	0	0	0	0	0	744	0.00	64088.856	64088.9	100.000
400 KV NSLG-KSNE- II	4	11	0	0	0	0	0	56	744	4.18	64088.856	63728.5	99.438
400 KV KSNE-NPRN-I	7	52	0	0	0	0	0	48	744	7.87	45343.374	44863.9	98.943
400 KV KSNE-NPRN-II	7	45	0	0	0	0	1	16	744	7.75	45343.374	44871.0	98.958
400 KV NPRN-MUZ-I	19	26	0	0	0	0	3	9	744	19.43	125705.837	122422.4	97.388
400 KV NPRN-MUZ-II	20	22	0	0	0	0	1	55	744	20.37	125705.837	122264.7	97.263
220 KV MUZ-KANTI-I	0	0	0	0	0	0	8	42	744	0.00	3174.6	3174.6	100.000
220 KV MUZ-KANTI-II	0	0	0	0	0	0	8	43	744	0.00	3174.6	3174.6	100.000
	57	156	0	0	0	0	21	269	5952		476625.334	468588.63	791.989

Availability 0.98314
 % Availability 98.314