



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति
Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

Faxmsg No - 715

Tel No. :033-2423 5016
FAX No.:033-2417 1358
Website: www.erpc.gov.in

No-ERPC/MS/TA/PL/2016/ 1066

Date-26.10.2016

To,


The Executive Director (ED & CEO),
Powerlinks Transmission Ltd,
10th Floor, DLF Tower-A,
District Centre-Jasola, New Delhi-110025

Certificate of availability of Powerlinks Transmission elements in eastern region for the month of July-16 & August-16

Availability for Intra Regional Lines of Powerlinks Transmission elements in eastern region (%)* for

Month	Availability
July, 2016	100.000 %
August, 2016	100.000 %

* Calculations as per CERC Regulations effective from 01.04.2014


(A. K. Bandyopadhyaya)
Member Secretary

Copy to: General Manager (O&P), Powerlinks Transmission Limited, Bidyut Nagar, Jalpaiguri, West Bengal, Pin-734015 (Fax: 0353 2568856)

JULY

Availability Calculation for the month of July 16 for Powerlink Lines in ER

2016

Element Name	Attributable to PL		Attributable to Others		Act of God/Grid Incident		Outage Under the Category of Deemed		Ti	TNAi	Wi (SIL*Ckt Km)	Wi(Ti-TNAi)/Ti	100*Wi(Ti-TNAi)/(Ti*Wi)
	Hrs	Mins	Hrs	Mins	Hrs	Mins	Hrs	Min					
400 KV NSLG-NPRN-III									744	0.00	79080.508	79081	100.000
400 KV NSLG-NPRN-IV									744	0.00	109976.334	109976	100.000
400 KV NPRN-MUZ-I									744	0.00	125705.837	125705.8	100.000
400 KV NPRN-MUZ-II			9	58					734.0333	0.00	125705.837	125705.8	100.000
220 KV MUZ-KANTI-I									744	0.00	3174.6	3174.6	100.000
220 KV MUZ-KANTI-II									744	0.00	3174.6	3174.6	100.000
	0	0	9	58	0	0	0	0	4454.033		446817.716	446817.7	

Availability 1.000
 % Availability 100.000


AUGUST

Availability Calculation for the month of August 16 for Powerlink Lines in ER

2016

Element Name	Attributable to PL		Attributable to Others		Act of God/Grid Incident		Outage Under the Category of Deemed available		Ti	TNAi	Wi (SIL*Ckt Km)	Wi(Ti-TNAi)/Ti	100*Wi(Ti-TNAi)/(Ti*Wi)
	Hrs	Mins	Hrs	Mins	Hrs	Mins	Hrs	Min					
400 KV NSLG-NPRN-III									744	0.00	79080.508	79081	100.000
400 KV NSLG-NPRN-IV									744	0.00	109976.334	109976	100.000
400 KV NPRN-MUZ-I			1	5					742.9167	0.00	125705.837	125705.8	100.000
400 KV NPRN-MUZ-II									744	0.00	125705.837	125705.8	100.000
220 KV MUZ-KANTI-I			1	36					742.4	0.00	3174.6	3174.6	100.000
220 KV MUZ-KANTI-II			2	0	0	9			741.85	0.00	3174.6	3174.6	100.000
	0	0	4	41	0	9	0	0	4459.167		446817.716	446817.7	

Availability 1.000
 % Availability 100.000


 Member Secretary