



सत्यमेव जयते

भारत सरकार  
Government of India

विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



Tel No.:033-24239650. 24239651 FAX No.:033-24239652. 24239653 Web: [www.ernc.gov.in](http://www.ernc.gov.in)

No-ERPC/MS/TA/PL/2017-18/

Date-12.07.2018

To,

The Executive Director (ED & CEO),  
Powerlinks Transmission Ltd,  
10<sup>th</sup> Floor, DLF Tower-A,  
District Centre- Jasola, New Delhi-110025

**Certificate of availability of Powerlinks Transmission elements in eastern region for the month of May-2018**

Availability for Intra Regional Lines of Powerlinks Transmission elements in eastern region (%)<sup>\*</sup>  
for

| Month     | Availability |
|-----------|--------------|
| May, 2018 | 99.995%      |

\* Calculations as per CERC Regulations effective from 01.04.2014



(J. Bandyopadhyay)  
Member Secretary

Copy to: General Manager (O&P), Powerlinks Transmission Limited, Bidyut Nagar, Jalpaiguri, West Bengal, Pin-734015 (Fax: 0353 2568856)

**Availability Calculation for the month of May ,2018 for Powerlink Lines in ER**

| Element Name         | Attributable to PL |      | Attributable to Others |      | Act of God/Grid Incident |      | Outage Under the Category of Deemed |     | Ti     | TNAi | Wi (SIL*Ckt Km) | Wi(Ti-TNAi)/Ti | 100*Wi(Ti-TNAi)/(Ti*Wi) |
|----------------------|--------------------|------|------------------------|------|--------------------------|------|-------------------------------------|-----|--------|------|-----------------|----------------|-------------------------|
|                      | Hrs                | Mins | Hrs                    | Mins | Hrs                      | Mins | Hrs                                 | Min | Hrs    | Hrs  |                 |                |                         |
| 400 KV NSLG-KSNE-I   | 0                  | 18   | 0                      | 0    | 0                        | 50   | 0                                   | 0   | 743.2  | 0.30 | 64088.856       | 64063.0        | 99.960                  |
| 400 KV NSLG-KSNE- II | 0                  | 0    | 0                      | 0    | 0                        | 0    | 0                                   | 0   | 744.0  | 0.00 | 64088.856       | 64088.9        | 100.000                 |
| 400 KV KSNE-NPRN-I   | 0                  | 0    | 0                      | 0    | 0                        | 0    | 0                                   | 0   | 744.0  | 0.00 | 45343.374       | 45343.4        | 100.000                 |
| 400 KV KSNE-NPRN-II  | 0                  | 0    | 0                      | 0    | 0                        | 0    | 0                                   | 0   | 744.0  | 0.00 | 45343.374       | 45343.4        | 100.000                 |
| 400 KV NPRN-MUZ-I    | 0                  | 0    | 0                      | 0    | 0                        | 0    | 0                                   | 0   | 744.0  | 0.00 | 125705.837      | 125705.8       | 100.000                 |
| 400 KV NPRN-MUZ-II   | 0                  | 0    | 0                      | 0    | 0                        | 0    | 0                                   | 0   | 744.0  | 0.00 | 125705.837      | 125705.8       | 100.000                 |
| 220 KV MUZ-KANTI-I   | 0                  | 0    | 0                      | 32   | 0                        | 26   | 0                                   | 0   | 743.0  | 0.00 | 3174.6          | 3174.6         | 100.000                 |
| 220 KV MUZ-KANTI-II  | 0                  | 0    | 0                      | 0    | 0                        | 0    | 0                                   | 0   | 744.0  | 0.00 | 3174.6          | 3174.6         | 100.000                 |
|                      | 0                  | 18   | 0                      | 32   | 0                        | 76   | 0                                   | 0   | 5950.2 |      | 476625.334      | 476599.46      | 799.960                 |

Availability

0.99995

% Availability

99.995